



Maine Department of Environmental Protection Underground/Aboveground Oil Storage Tank Facility Notification of Temporarily Out-of-Service Tank(s) Form

Maine's Ground Water Protection Law and the Department's Rules for Underground Oil Storage Facilities, Chapter 691, require the owner of an underground oil storage facility to amend the registration with the Department to reflect any changes in ownership, tank use, or facility upgrades.

The underground oil storage tank listed below will be kept out-of-service for a period not to exceed 12 months. By submitting this form, I certify that:

A. The corrosion protection system is being operated and maintained (cathodically protected steel, only)

*******(Please check one under b.)*******

B. Leak detection is continuing in accordance with applicable Rules, Chapter 691

or

All product has been removed from the tank with no more than one (1) inch of residual left

C. Vent lines are open and functioning

D. All other lines, pumps, man ways and ancillary equipment are capped and secured

I will report and investigate evidence of a possible leak or discharge to the Department within 24 hours of discovery.

Facility Information

Facility Name: _____		Reg. #: _____	
Mailing Address: _____			
Address	Town	State	Zip Code
Tank #:	Tank Size:	Product Stored:	
Tank #:	Tank Size:	Product Stored:	
Tank #:	Tank Size:	Product Stored:	
Reason for temporary abandonment: _____			
Date tank taken out of service: _____		Today's date: _____	
Signature of Facility Owner or Operator: _____			

Please complete all applicable sections to update the Department's records, either by hand printing or typing. Be sure to sign the completed form. Please keep a copy of this form for your records and submit original to:

Maine Department of Environmental Protection
Attn: Tank Registration Staff, 17 State House Station
Augusta, Maine 04333
Phone #: (207) 287-2651

Note: State law and DEP Rules require removal of an underground tank or facility that is out of service for more than 12 months (1 year), unless the tank owner has requested in writing approval for the tank to remain temporarily out-of-service for more than 12 months before expiration of the initial 12 months period. The Commissioner may grant approval under a limited set of circumstances.