



JOHN ELIAS BALDACCI
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

January 29, 2008
Subject: Bowdoin
Project No. BR-1262(100)X
PIN: 012621.00
Amendment No. 1

DAVID A. COLE
COMMISSIONER

Dear Sir/Ms.:

Please make the following changes to your Bid Documents:

Delete the "Schedule of Items" dated 071219 three pages total, and replace with the attached "Schedule of Items" dated 080128, three pages total.

Please make the following changes to the Contract Plans.

On Sheet 2 of 19, titled "Estimated Quantities", **delete** line 639.19- Field Office Type B-1EA from the Estimated Quantities Table. Make this change with pen and ink.

On Sheet 2 of 19, titled "Estimated Quantities", **delete** line 203.25-Granular Borrow-170CY, and **replace** with 203.25-Granular Borrow- 600CY in the Estimated Quantities Table. Make this change with pen and ink.

On Sheet 16 of 19, titled "Aluminum Box Culvert", **delete** note 1 of Aluminum Box Culvert Notes and **replace** with "1. One 23'-0" x 6'-1" rise structural plate box culvert is required. The box shall have a full invert with toe walls at both ends. Headwalls and Wingwalls are as shown. Thickness of haunch plates shall be 0.25 inches and invert plates shall be 0.100 inches. Thickness of Crown plates shall be 0.25 inches." Make this change with pen and ink.

The following requests for Information were submitted:

Question: With the short duration of this project, the long lead time to set up utilities (esp. DSL) and in interest of saving money on the project, would the Dept. consider removing the 639.19 Office Trailer item from the schedule of items?

Response: Item 639.19 "Office Trailer" has been removed from this Contract as referenced in this amendment.

Question: Please clarify the aluminum box plate thickness requirements. The thickness, as shown on the plans, is not available.

Response: Plate thickness is 0.25 for all plates as referenced in this amendment.



PRINTED ON RECYCLED PAPER

Question: There is no Special Provision for Item #509.411. Please clarify what is incidental to that.

Response: Please see the "State of Maine, Department of Transportation, Standard Specifications Revisions of 2002".

Question: I have taken off the Granular Borrow for this project and have come up with close to 900 cy but the bid quantity is only 170 cy. Also, there is no bid item for Structural Excavation, and no Special Provision 509.41 for this project, if this is bid by the standard 509 the Granular Borrow for the culvert and wings should be unit priced As well as the Structural Ex. Am I missing a note on the plans? All I have seen is note 18 on sheet 2 for incidentals to 509.411.

Response: The Granular Borrow quantity has been changed to 600 CY as referenced in this amendment. Excavation for items paid for under 509.411 shall be paid for under Item 509.411.

Question: The Special Provisions for Section 652 states that the Contractor is responsible for temporary pavement markings. Is this correct?

Response: If Temporary Pavement markings are used, the Contractor will be responsible for removing them.

Question: It appears that the maximum time allowed for the road closure may not be enough time. Is it possible to extend the time from 5 days to 10 days?


Response: No, we have an agreement with the Town for a five day closure.

Question: I have received several calls from various suppliers regarding the bolts used to connect/fasten the aluminum plate arch pieces together. These suppliers are wondering if the bolts must be aluminum or can they be galvanized. If you could please tell me if both types of bolts are acceptable, it would be appreciated.

Response: Bolts must be aluminum.

Consider these changes and information prior to submitting your bid on January 30, 2008.

Sincerely,



Scott Bickford

Contracts & Specifications Engineer

MAINE DEPARTMENT OF TRANSPORTATION

PAGE: 1

SCHEDULE OF ITEMS

DATE: 080128

REVISED:

CONTRACT ID: 012621.00

PROJECT(S): BR-1262(100)X

CONTRACTOR : _____

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS

SECTION 0001 BRIDGE ITEMS

0010	202.19 REMOVING EXISTING BRIDGE	LUMP		LUMP			
0020	203.20 COMMON EXCAVATION	202.000 CY					
0030	203.24 COMMON BORROW	415.000 CY					
0040	203.25 GRANULAR BORROW	600.000 CY					
0050	304.10 AGGREGATE SUBBASE COURSE - GRAVEL	569.000 CY					
0060	509.411 ALUMINUM STRUCTURAL PLATE BOX CULVERT	LUMP		LUMP			
0070	511.07 COFFERDAM: DOWN STREAM	LUMP		LUMP			
0080	511.07 COFFERDAM: UP STREAM	LUMP		LUMP			
0090	603.21 36 INCH CULVERT PIPE OPTION I	52.000 LF					
0100	606.23 GUARDRAIL TYPE 3C - SINGLE RAIL	325.000 LF					

MAINE DEPARTMENT OF TRANSPORTATION

PAGE: 2

SCHEDULE OF ITEMS

DATE: 080128

REVISED:

CONTRACT ID: 012621.00

PROJECT(S): BR-1262(100)X

CONTRACTOR :

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0110	606.231 GUARDRAIL TYPE 3C - 15 FOOT RADIUS AND LESS	25.000 LF				
0120	606.265 TERMINAL END - SINGLE RAIL - GALVANIZED STEEL	1.000 EA				
0130	606.353 REFLECTORIZED FLEXIBLE GUARDRAIL MARKER	8.000 EA				
0140	606.79 GUARDRAIL 350 FLARED TERMINAL	3.000 EA				
0150	610.08 PLAIN RIPRAP	89.000 CY				
0160	615.07 LOAM	76.000 CY				
0170	618.14 SEEDING METHOD NUMBER 2	8.000 UN				
0180	619.12 MULCH	8.000 UN				
0190	619.1401 EROSION CONTROL MIX	151.000 CY				
0200	620.58 EROSION CONTROL GEOTEXTILE	133.000 SY				
0210	629.05 HAND LABOR, STRAIGHT TIME	10.000 HR				

SCHEDULE OF ITEMS

CONTRACT ID: 012621.00

PROJECT(S): BR-1262(100)X

CONTRACTOR : _____

LINE NO	ITEM DESCRIPTION	APPROX. QUANTITY AND UNITS	UNIT PRICE		BID AMOUNT	
			DOLLARS	CTS	DOLLARS	CTS
0220	631.12 ALL PURPOSE EXCAVATOR (INCLUDING OPERATOR)	10.000 HR				
0230	631.15 ROLLER, EARTH AND BASE COURSE (INCLUDING OPERATOR)	10.000 HR				
0240	631.171 TRUCK - SMALL (INCLUDING OPERATOR)	10.000 HR				
0250	637.071 DUST CONTROL	LUMP	LUMP			
0260	652.39 WORK ZONE TRAFFIC CONTROL	LUMP	LUMP			
0270	656.75 TEMPORARY SOIL EROSION AND WATER POLLUTION CONTROL	LUMP	LUMP			
0280	659.10 MOBILIZATION	LUMP	LUMP			
	SECTION 0001 TOTAL					
	TOTAL BID					