



STATE OF MAINE  
DEPARTMENT OF TRANSPORTATION  
16 STATE HOUSE STATION  
AUGUSTA, MAINE  
04333-0016

JOHN ELIAS BALDACCI  
GOVERNOR

DAVID A. COLE  
COMMISSIONER

September 29, 2009  
Subject: **Gray**  
State Pin No.015980.00  
**Amendment No. 2**

Dear Sir/Ms:

The following questions have been received:

**Question:** Could you please provide additional information as to the requirements of the box culvert? What are the minimum rise requirements of the box culvert?

**Response:** The minimum rise is the maximum rise which meets the requirements of; minimum span of the structure and the minimum depth of cover as specified and the existing center line elevation unchanged.

**Question:** The special provision for the box culvert references precast concrete headwalls and wingwalls. Do these components have to be precast concrete?

**Response:** Special Provision 509 requires concrete footings, and reinforced concrete headwalls, wingwalls and bridge transition curbs. There is no mention of "precast".

**Question:** Reference Item No. 606.74, Bridge Mounted Guardrail. Is this the correct item? There is no bridge to mount to.

**Response:** The Guardrail attaches to the headwall of the new structure.

Consider this information prior to submitting your bid on **September 30, 2009**.

Sincerely,

Scott Bickford  
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER