



JOHN ELIAS BALDACCI
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE
04333-0016

DAVID A. COLE
COMMISSIONER

November 16, 2009
Subject: **Manchester**
Federal Project No: 004270.10D
State Pin No: 004270.10D
Amendment No. 2

Dear Sir/Ms:

The following question has been received:

Question: What type of fence should be used for the enclosure?

Response: The fence shall meet the requirements of Standard Specification Item 607.16 Chain Link Fence – 1.2m (4 ft) as shown on page 28 of the Bid Book. The length of control of access is approximately 300’.

Consider this information prior to submitting your bid on November 18, 2009.

Sincerely,

A handwritten signature in dark ink, appearing to read "S. Bickford".

Scott Bickford
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER