STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

Paul R. LePage
GOVERNOR

David Bernhardt
COMMISSIONER

November 4, 2014
Subject: **Bridge replacement**
State WIN: 018234.00
Location: **Waterville**
Amendment No. 1

Dear Sir/Ms:

The following question has been received:

Question: What is the reinforcing type for the Next D Beams, Epoxy/Dual Coated/Stainless Steel, for the Western Avenue Bridge in Waterville??

Response: The reinforcement within the NEXT Beams will be uncoated rebar.

Consider this information prior to submitting your bid on **November 19**, 2014.

Sincerely,

for George M. A. Macdougall P.E.
Contracts & Specifications Engineer