



Paul R. LePage
GOVERNOR

STATE OF MAINE
DEPARTMENT OF TRANSPORTATION
16 STATE HOUSE STATION
AUGUSTA, MAINE 04333-0016

David Bernhardt
COMMISSIONER

September 23, 2014
Subject: **M & O**
NO WIN: PH20140903RR
Location: **Scarborough**
Amendment No. 1

Dear Sir/Ms:


The following question has been received:

Question: On the schedule of items you are requesting a unit price for 1000 square feet of insulation replacement. What thickness of insulation are we to base this price? Prices vary based on thickness so we either need to know the thickness or base the price on a board foot which can be multiplied by the thickness once discovered, please advise.

Response: We think there are two layers of 1.5" polyisocyanurate so bid accordingly. The Contractor should bid accordingly.

Consider this change and information prior to submitting your bid on **September 24th, 2014.**

Sincerely,


George M. A. Macdougall P.E.
Contracts & Specifications Engineer



PRINTED ON RECYCLED PAPER