

West Springfield Fire Department

44 Van Deene Avenue
West Springfield MA 01089
413-732-2650

Food Service Fire Safety Inspection

Event Title:	From:	To:
Event Location:		

Vendor Information

Vendor Name:	Phone:
Contact:	Phone:
Address:	
Location within event:	
Facility Type:	Tent Mobile Food Truck Trailer Other

FAIL ANY TANK = FAIL CATEGORY

LP Gas Cylinder Identification Marks (neck-ring or shoulder of tank)				PASS	FAIL
1	Quantity of tanks:	DOT stamped: Y	N		
2	Cylinder Size: 20# x 30# x 40# x 100# x				
3	Inspector's Mark present (located between month/year of manufacture):				
4	Manufacture Date (month/year):				
	Tank 1:	Tank 2:	Tank 3:	Tank 4:	
5	Requalified/Retested Date (<12 years from manufacture date):				
	Tank 1:	Tank 2:	Tank 3:	Tank 4:	


LP Gas Cylinder Visual Inspection

		PASS	FAIL
6	Cylinder Exterior (no evidence of physical abuse, heat damage, detrimental rust or corrosion)		
7	Cylinder Foot-Ring, Neck-Ring and/or Valve Cover in good condition		
8	Regulator (no evidence of leakage; relief directed away from tent/canopy and ignition sources)		
9	Tank Secured (strapped to stable anchor)	N/A	
10	Footing Level/Stable (pavement, stone/block or cement pad)	N/A	
11	Supply Hose (looped at tank and appliance)	N/A	

Cooking Area Inspection

		PASS	FAIL
12	Hood Inspected/Cleaned:		
13	Suppression System Inspected:		
14	ABC Fire Extinguisher Inspected:		
15	"K" Class Fire Extinguisher Inspected:		

Propane cylinders have identifying marks on the cylinder neckring (collar), or cylinder shoulder depending on the cylinder type. The diagram below depicts examples of several of the required markings.



- Ⓐ Manufactured to U.S. DOT specifications
- Ⓑ Cylinder specification type (e.g. 4B, 4BA, 4BW, and 4E)
- Ⓒ Cylinder service pressure (psig)
- Ⓓ Cylinder serial number
- Ⓔ Manufacturer's name (or registered symbol)
- Ⓕ Original manufacture/test date, month and year, and inspector's mark, as required (i.e., this diagram indicates April 1994 and inspector's mark ♦)
- Ⓖ Area for date requalified/retested (no date is shown indicating that the 12-year requalification is overdue)

* Additional markings may be present as authorized by HMR under the specification

Inspector:	Date:	Approved	Denied
------------	-------	----------	--------