

# West Springfield Fire Department

44 Van Deene Avenue  
West Springfield MA 01089  
413-732-2650

## Food Service Fire Safety Inspection

Event Title:	From:	/	/	2016	To:	/	/	2016
Event Location:								

Vendor Information			
Vendor Name:			Phone:
Contact:			Phone:
Address:			
Location within event:			
Facility Type:	Tent [ ]	Mobile Food Truck [ ]	Trailer [ ]

LP Gas Cylinder Identification Marks (neck-ring or shoulder of tank)			
1	Manufactured to U.S. DOT specifications	PASS	FAIL
2	Cylinder Specification Type:      4B   4BA   4BW   4E	PASS	FAIL
3	Manufactured by:	PASS	FAIL
4	Cylinder Water Capacity:                      Cylinder Service Pressure (psig):	PASS	FAIL
5	Cylinder Serial Number:	PASS	FAIL
6	Manufacture/Test Date (month/year and inspector's mark):	PASS	FAIL
7	Date Requalified/Retested:	PASS	FAIL

LP Gas Cylinder Visual Inspection			
1	Damage to cylinder exterior; dents, bulges, cuts or cracks on surface or welds; and or evidence of physical abuse, fire or heat damage.	PASS	FAIL
2	Detrimental rust, corrosion, or pitting on the cylinder, particularly on the bottom.	PASS	FAIL
3	Absence of/damage to cylinder foot-ring, neck-ring (collar) or valve cover.	PASS	FAIL
4	Leaking or defective valve or pressure relief device (relief directed away from tent/canopy and ignition sources)	PASS	FAIL
5	Regulator (visual only)	PASS	FAIL
6	Supply Hose (looped at tank and appliance)	PASS	FAIL
7	Tank Secured (strapped/tied to stake or water barrel)	PASS	FAIL
8	Footing (pavement, stone or cement block or pad)	PASS	FAIL

Cooking Area Inspection			
1	Hood: Inspected    / /                      By:	PASS	FAIL
2	Suppression System: Inspected    /    /                      By:	PASS	FAIL
3	ABC Fire Extinguisher: Inspected    /    /	PASS	FAIL
4	"K" Class Fire Extinguisher: Inspected    /    /	PASS	FAIL

Inspector:	Date:
------------	-------