



Maine CDC Health Inspection Program

Swimming Pool/Spa Log (Retain for 1 year)

Name of Pool/Spa: _____ Located at: _____ Week of _____ to _____ 20__

Day	Spa		Pool Cleaning		Pump Room Maintenance				Chemicals or Water Added (in Pounds, Tablets or Gallons)						
	# of Bathers	Water Temp (°F) ¹	Bottom and Walls	Skimmer Baskets	Pump Basket Emptied	Filter Pressure	Flow Rate (GPM)	Back Washed	Sanitizer	Acid	Soda Ash	Algaecide	Super-chlorination	Water	Other
Sunday															
Monday															
Tuesday															
Wednesday															
Thursday															
Friday															
Saturday															

Day	Daily Readings ²			Disinfectant Residual			Total Chlorine	Combined Chlorine ³	CPO Initials	Weekly Readings ²	Cyanuric Acid	Calcium Hardness	Alkalinity
	Opening	pH Mid-Session	Closing	Opening	Mid-session	Closing							
Sunday										Comments:			
Monday													
Tuesday													
Wednesday													
Thursday													
Friday													
Saturday													

¹ Must be 104°F or less for Spas ²For chemical parameters see Appendix A and for frequency see Appendix D of the **State of Maine Rules Relating To Public Pools and Spas (10-144 CMR, Chapter 202)** ³ Combined Chlorine = Total Chlorine – Free Chlorine (for pools must be ≤ 0.2 ppm, for spas ≤ 0.5 ppm)